



INSTALL CONC. BENCH IN BOTTOM OF MANHOLE AS SHOWN TO EXISTING SEWER OUTLET

4" BEDDING

PRECAST RUBBER BOOT PER ASTM C923

CONCRETE SHALL BE MINIMUM OF 4000 PSI @28 DAYS FILLED UNDER PIPE TO UNDISTURBED GROUND. CONCRETE TO EXTEND TO FIRST JOINT IN NORMAL WIDTH OF TRENCH.

SECTION A - A

PLAN VIEW

NOTES:

1. DROP CONNECTIONS ARE NOT ALLOWED.
2. MAXIMUM OF ONE FORCEMAIN CONNECTION PER MANHOLE; MULTIPLE CONNECTIONS NOT ALLOWED.

NOT TO SCALE



TECHNICAL GUIDANCE MANUAL

TYPICAL FORCEMAIN DISCHARGE TO GRAVITY MANHOLE

7/1/12

STD. DWG. NO. 35

PAGE NO. 36