


Protecting Our Water Environment



Metropolitan Water Reclamation District of Greater Chicago

***RESEARCH AND DEVELOPMENT
DEPARTMENT***

REPORT NO. 08-58

***BIOMONITORING REPORT
2008***

***ACUTE WHOLE EFFLUENT TOXICITY TEST RESULTS
FOR THE JAMES C. KIRIE WATER RECLAMATION PLANT
DES PLAINES, ILLINOIS***

***NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
PERMIT NUMBER IL0047741, AUGUST 2008***

OCTOBER 2008

Terrence J. O'Brien
President
Kathleen Therese Meany
Vice President
Gloria Alitto Majewski
Chairman of Finance
Frank Avila
Patricia Horton
Barbara J. McGowan
Cynthia M. Santos
Debra Shore
Patricia Young

Metropolitan Water Reclamation District of Greater Chicago

100 EAST ERIE STREET CHICAGO, ILLINOIS 60611-3154 312-751-5600

Louis Kollias, P.E., BCEE
Director of Research and Development

312-751-5190

October 3, 2008

Mr. Roger Calloway
Environmental Specialist
Compliance Assurance Section - 19
Illinois Environmental Protection Agency
1021 North Grand Avenue
Springfield, IL 62794-9276

Dear Mr. Calloway:

Subject: Biomonitoring Report for August 2008 – James C. Kirie Water Reclamation Plant, National Pollutant Discharge Elimination System Permit Number IL0047741

The subject biomonitoring report is submitted in compliance with the National Pollutant Discharge Elimination System Permit Number IL0047741, Special Condition 11. Whole effluent toxicity tests were conducted in accordance with the biomonitoring plan for the Kirie Water Reclamation Plant, dated October 8, 2007.

The subject report includes copies of all bench sheets, chain-of-custody forms, sample receipt and preparation forms, hard copies of computer generated statistical analyses, control charts, and a certification of accuracy statement.

If you have any questions concerning this report, please contact Dr. Geeta Rijal, Microbiologist IV, at 708-588-4224.

Very truly yours,

Louis Kollias
Director
Research and Development

LK:GR:ss
Enclosures
cc w/enc: Jamjun/Gronski/Grabis/Granato
Moscinski/O'Connor/Rijal/Glymph
Yamanaka
cc: Cohen (Transmittal letter and report title page)

Metropolitan Water Reclamation District of Greater Chicago
100 East Erie Street Chicago, IL 60611-2803 (312) 751-5600

BIOMONITORING REPORT
2008

ACUTE WHOLE EFFLUENT TOXICITY TEST RESULTS
FOR THE JAMES C. KIRIE WATER RECLAMATION PLANT
DES PLAINES, ILLINOIS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
PERMIT NUMBER IL0047741, AUGUST 2008

Research and Development Department
Louis Kollias, Director

OCTOBER 2008

TABLE OF CONTENTS

	<u>Page</u>
LIST OF TABLES	iii
ACKNOWLEDGEMENTS	iv
DISCLAIMER	iv
ACUTE WHOLE EFFLUENT TOXICITY TEST RESULTS FOR THE JAMES C. KIRIE WATER RECLAMATION PLANT, DES PLAINES, ILLINOIS, NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT NUMBER IL0047741, AUGUST 2008	1
Summary	1
Sample Information	1
Whole Effluent Toxicity Tests	1
Analysts	3
Results	3
CERTIFICATION OF ACCURACY	6
APPENDICES	
AI Summary of Acute Toxicity Results <i>Pimephales promelas</i> CETIS Test Summary and Comparison Report	AI-1
AII Summary of Acute Toxicity Results <i>Ceriodaphnia dubia</i> CETIS Test Summary and Comparison Report	AII-1
BI Raw Data for <i>Pimephales promelas</i> Whole Effluent Toxicity Test Conducted on James C. Kirie Water Reclamation Plant Final Effluent Collected on August 4-5, 2008	BI-1
BII Raw Data for <i>Ceriodaphnia dubia</i> Whole Effluent Toxicity Test Conducted on James C. Kirie Water Reclamation Plant Final Effluent Collected on August 4-5, 2008	BII-1

TABLE OF CONTENTS (Continued)

APPENDICES		<u>Page</u>
CI	Chain-of-Custody for Whole Effluent Toxicity Tests Conducted on James C. Kirie Water Reclamation Plant Final Effluent Collected on August 4-5, 2008	CI-1
DI	Quality Assurance for the <i>Pimephales promelas</i> Whole Effluent Toxicity Test: Raw Data and Statistical Calculations for the Concurrent Reference Toxicant Test, Control Charts, and Culture Data	DI-1
DII	Quality Assurance for the <i>Ceriodaphnia dubia</i> Whole Effluent Toxicity Test: Raw Data and Statistical Calculations for the Concurrent Reference Toxicant Tests, Control Charts, and Culture Data	DII-1

LIST OF TABLES

<u>Table No.</u>		<u>Page</u>
1	Sample Collection Information	2
2	Acute <i>Pimephales promelas</i> Test Results	4
3	Acute <i>Ceriodaphnia dubia</i> Test Results	5

ACKNOWLEDGEMENTS

Ms. Susan M. Schaefer is acknowledged for typing this report.

DISCLAIMER

Mention of proprietary equipment and chemicals in this report does not constitute endorsement by the Metropolitan Water Reclamation District of Greater Chicago.

ACUTE WHOLE EFFLUENT TOXICITY TEST RESULTS FOR THE
JAMES C. KIRIE WATER RECLAMATION PLANT, DES PLAINES, ILLINOIS
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
PERMIT NUMBER IL0047741, AUGUST 2008

Summary

The acute toxicity test with the fathead minnow, *Pimephales promelas* (*P. promelas*) [96-hour, static, renewal], was conducted on samples of James C. Kirie Water Reclamation Plant (WRP) final effluent collected on August 4-5, 2008. The fathead minnow results indicated a valid test. No acute toxicity to *P. promelas* was observed. Results of the quality control acute toxicity test with fathead minnow using the reference toxicant sodium chloride fell within control chart limits prescribed as acceptable by the United States Environmental Protection Agency (USEPA).

The acute toxicity test with the *Ceriodaphnia dubia* (*C. dubia*) [48-hour, static, nonrenewal] was conducted on samples of James C. Kirie WRP final effluent collected on August 4-5, 2008. Test results indicated a valid test. No acute toxic effect to *C. dubia* was observed. One hundred percent of the *C. dubia* organisms exposed to five effluent test concentrations survived, indicating no *C. dubia* toxicity. Results of the concurrent quality control acute toxicity test using the reference toxicant sodium chloride fell within control chart limits prescribed as acceptable by the USEPA.

Sample Information

Five grab samples of James C. Kirie WRP final effluent were collected at 0600, 1200, 1800 and 2400 on Monday, 08/04/08 and 0600 on Tuesday, 08/05/08 for the acute toxicity test with *P. promelas* and *C. dubia*. The individual grab samples were stored on site at 0.1-6°C in a refrigerator. These samples were received in the laboratory within 4 hours of the final grab sample collection. Sample temperatures at the time of receipt were below 9°C. The five samples were combined in the laboratory to make a 24-hour composite sample. Samples were stored in a locked refrigerator in the laboratory at 4 ± 1°C. Sample collection information is shown in Table 1.

Whole Effluent Toxicity Tests

The acute *P. promelas* and the acute *C. dubia* Whole Effluent Toxicity (WET) tests were conducted on the James C. Kirie WRP effluent samples collected on August 4-5, 2008. The acute WET test methods and procedures were followed in accordance with *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms*, EPA/821-R-02-012, Fifth Edition, October 2002. *P. promelas* were exposed to 6.25, 12.5, 25, 50, and 100% effluent concentrations for 96 hours. *C. dubia* were exposed to the same concentrations of effluent for 48 hours. The acute *P. promelas* test was set up on August 5, 2008 and

TABLE 1: SAMPLE COLLECTION INFORMATION

Effluent Collection Point:	James C. Kirie Water Reclamation Plant Effluent Discharge Number 001
Effluent Collection Method:	Composite sample of five grab samples collected in a 24-hour period
Effluent Water Collection Date and Sample Time:	August 4, 2008 - 0600, 1200, 1800, 2400 August 5, 2008 - 0600

completed on August 9, 2008. The acute *C. dubia* test was set up on August 5, 2008 and completed on August 7, 2008. Hard synthetic water (HSW) with selenium was used as control and dilution water. Statistical analyses were performed using the CETIS™ Software program version 1.6.3 revE (Tidepool Scientific Software, California).

Concurrent reference toxicant tests (RTT) using sodium chloride (NaCl) were conducted and the control charts for the fathead minnow and the *C. dubia* acute RTT were prepared.

Analysts

Vince Billett (Laboratory Technician II), Hema Shukla (Laboratory Technician II), and Jon Yamanaka (Biologist I) conducted the WET tests. Jon Yamanaka entered the raw data in an Excel and CETIS™ program. Jon Yamanaka, Auralene Glymph (Microbiologist III), and Geeta Rijal (Microbiologist IV) prepared this report.

Results

Results of the acute WET test with *P. promelas* are shown in Table 2. The *P. promelas* test results indicated a valid test. No acute toxicity to *P. promelas* was observed. The HSW control water met the test acceptability criteria (>90% survival) for the *P. promelas* test. Results of the quality control acute toxicity test with *P. promelas* using the RTT fell within limits prescribed as acceptable by the USEPA, i.e. within ± 2 standard deviations from the mean.

Results of the acute WET test with *C. dubia* are shown in Table 3. The *C. dubia* test results indicated a valid test. There was no acute toxicity to *C. dubia* organisms exposed to five effluent test concentrations. The HSW control water met the test acceptability criteria (>90% survival) for the *C. dubia* test. Results of the quality control acute toxicity test with *C. dubia* using the RTT fell within limits prescribed as acceptable by the USEPA, i.e. within ± 2 standard deviations from the mean.

The WET test results indicated no acute toxicity to *P. promelas* and *C. dubia*. Tabulated summaries of the *P. promelas* and *C. dubia* WET tests are presented in Appendices AI and AII, respectively. Raw data for the *P. promelas* and *C. dubia* tests are presented in Appendices BI and BII, respectively. Chain-of Custody documentation is provided in Appendix CI. Raw data, statistical calculations, and control charts for the *P. promelas* and *C. dubia* concurrent reference toxicant tests are provided in Appendices DI and DII, respectively.

TABLE 2: ACUTE *PIMEPHALES PROMELAS* TEST RESULTS

96-h LC ₅₀	>100%
Toxicity Observed	No
Mean Percent Survival in Laboratory Water Control (HSW)	100%
Mean Percent Survival in 100 % Final Effluent	100%
Valid Test	Yes
Concurrent Reference Toxicant Test in Control	Yes

TABLE 3: ACUTE *CERIODAPHNIA DUBIA* TEST RESULTS

48-h LC ₅₀	>100%
Toxicity Observed	No
Mean Percent Survival in Laboratory Water Control (HSW)	100%
Mean Percent Survival in 100 % Final Effluent	100%
Valid Test	Yes
Concurrent Reference Toxicant Test in Control	Yes

CERTIFICATION OF ACCURACY

I certify under penalty of law that this document and all appendices were prepared under my supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations 40 C.F.R. 122.22 (d).

Date

Louis Kollias
Director
Research and Development

If you have any questions concerning this report, please contact Dr. Geeta Rijal, Microbiologist IV, at 708-588-4224.