

Protecting Our Water Environment



Metropolitan Water Reclamation District of Greater Chicago

*MONITORING AND RESEARCH
DEPARTMENT*

REPORT NO. 14-27

CALUMET WEST SOLIDS MANAGEMENT AREA

MONITORING REPORT FOR

SECOND QUARTER 2014

AUGUST 2014

Protecting Our Water Environment



Metropolitan Water Reclamation District of Greater Chicago

100 East Erie Street

Chicago, Illinois 60611-3154

312.751.5190

BOARD OF COMMISSIONERS

Kathleen Therese Meany

President

Barbara J McGowan

Vice President

Mariyana T. Spyropoulos

Chairman of Finance

Michael A. Alvarez

Frank Avila

Cynthia M. Santos

Debra Shore

Kari K. Steele

Patrick D. Thompson

THOMAS C. GRANATO, Ph.D.

Director of Monitoring and Research

312.751.5190 f: 312.751.5194

thomas.granato@mwr.org

August 13, 2014

Mr. S. Alan Keller, P.E.
Manager, Permit Section
Illinois Environmental Protection Agency
1021 North Grand Avenue East
P.O. Box 19276
Springfield, IL 62794 - 9276

Dear Mr. Keller:

Subject: Calumet West Solids Management Area - Calumet Water Reclamation Plant,
Illinois Environmental Protection Agency Permit No. 2010-AO-0265-1,
Monitoring Report for April, May, and June 2014

The attached tables contain the monitoring data for the Calumet West Solids Management Area for April, May, and June 2014 as required by Illinois Environmental Protection Agency (IEPA) Operating Permit No. 2010-AO-0265-1.

The data reported are as follows:

Table 1, Analysis of Water from Lysimeters L-1N through L-3N at the Calumet West Solids Management Area Sampled on May 7, 2014.

Table 2, Analysis of Compositated Biosolids Placed in the Calumet West Solids Management Area During May 2014.

Biosolids were placed in the solids drying area during May 2014. Based on the requirements of the revised IEPA permit issued on January 27, 2014, and effective immediately, analysis of biosolids removed from this site will no longer be reported under this permit. The list of parameters for lysimeter samples has also been modified to include only pH, Cl⁻, SO₄²⁻, and NO₂+NO₃-N.

Very truly yours,

Thomas C. Granato, Ph.D.
Director
Monitoring and Research

TCG:DB:cm

Attachment

cc w/att: Mr. J. Patel, IEPA
Records Unit, IEPA

TABLE 1: ANALYSIS OF WATER FROM LYSIMETERS L-1N THROUGH L-3N AT THE CALUMET WEST SOLIDS MANAGEMENT AREA SAMPLED ON MAY 7, 2014.

Parameter	Lysimeter No.		
	L-1N	L-2N	L-3N
pH ¹	8.0	7.7	7.8
	----- mg L ⁻¹ -----		
Cl ⁻	30	21	56
SO ₄ ²⁻	1,908	1,902	2,372
NO ₂ +NO ₃ -N	< 0.15	0.25	0.44

¹pH analyzed beyond recommended holding time of 15 minutes.

TABLE 2: ANALYSIS OF COMPOSITED BIOSOLIDS PLACED IN THE CALUMET WEST SOLIDS MANAGEMENT DRYING AREA DURING MAY 2014

Parameter	Analysis ¹
pH	7.5
Total Solids	---- % ----
Total Volatile Solids ²	6.9
	52

¹Mean of three samples.

²Total volatile solids as a percentage of total solids.