

NOTES:

- 1. STRUCTURE AND BAFFLE WALL FABRICATED USING PORTLAND CEMENT CONCRETE.
- 2. RESTRICTORS LESS THAN 4" IN DIAMETER MUST USE CITY OF CHICAGO VORTEX RESTRICTOR (SEE DETAIL)
- 3. BAFFLE WALL PERMANENTLY INSTALLED AS PRECAST OR CAST IN PLACE, (STEEL PLATE ACCEPTABLE IF PERMANENT).
- 4. PIPE TO STRUCTURE CONNECTIONS SHALL BE ASTM C923 IN COMBINED SEWER AREAS.

NOT TO SCALE

