

The Metropolitan

Water Reclamation District

of Greater Chicago

**WELCOME
TO THE JUNE EDITION
OF THE 2012
M&R SEMINAR SERIES**

HRSD

BEFORE WE BEGIN

- **SILENCE CELL PHONES & PAGERS**
- **QUESTION AND ANSWER SESSION WILL FOLLOW PRESENTATION**
- **SEMINAR SLIDES WILL BE POSTED ON MWRD WEBSITE AT ([www. MWRD.org](http://www.MWRD.org))**
- **Home Page ⇒ (Public Interest) ⇒ more public interest**
 - ⇒ **M&R Seminar Series ⇒ 2012 Seminar Series**

Charles B. Bott, Ph.D. P.E., BCEE

Career

Research and Development Manager at HRSD

Adjunct Professor in the Dept of Civil and Env Eng at Virginia Tech and Old Dominion University

Associate Professor in the Dept of Civil and Env Eng at the Virginia Military Institute (VMI)

Consulting Engineer with Parson Engineering Science

Professional

Registered Professional Engineer: Virginia

Board Certified Environmental Engineer (BCEE)

Board of Trustees, Water Environment Federation

Science and Technical Advisory Committee to the Chesapeake Bay Program Executive Council

Education

Ph.D in Civil and Env Eng, Virginia Tech;

MS in Env Eng, Johns Hopkins University

BS in Civil Eng, Virginia Military Institute, o

Awards

Winner of the WEF Harrison Prescott Eddy Medal

Winner of the Water Environment Federation (WEF) Outstanding Young Professional Award






Struvite Recovery at the HRSD Nansemond Treatment Plant

Charles B. Bott, PhD, P.E., BCEE


Hampton Roads Sanitation District



Hampton Roads Sanitation District


- Created in 1940
- Serves 1.6 million people
- Includes 17 jurisdictions – 3,100 square miles
- 9 plants, 4 small plants
- Capacity of 249 MGD

HRSD Service Area Map



◆ = treatment plant locations

HRSD's Bubble Permit - 2011



- James River
 - 6,000,000 lbs/yr TN
 - 573,247 lbs/yr TP
- York River
 - 288,315 lbs/yr TN
 - 33,660 lbs/yr TP
- Rappahannock River (one plant)
 - 1,218 lbs TN
 - 91 lbs/yr TP

Chesapeake Bay TMDL & VA WIP

- Nitrogen – James River
 - 2011 – 6.0 million pounds/year
 - Major upgrades ongoing at Nansemond, James River, Williamsburg, Army Base
 - Upgrade at Boat Harbor (minimal N removal)
 - 2017 – 4.4 million pounds/year
 - VIP - upgrade for improved denitrification
 - Small upgrade at Williamsburg possible
 - 2021 – 3.4 million pounds/year
 - Upgrade Chesapeake-Elizabeth (full plant)
- Nitrogen – York River ---- No change?
 - Rapid upgrade - denite filters for 2011 compliance
 - Upgrade needed for cost-effective BNR and reliability


HRSD Treatment and BNR R&D Program Focus

- Resource utilization:
 - Energy
 - Chemicals
 - Labor (operations, maintenance, instrumentation...)
 - Concrete
- Resource recovery
 - Water
 - P
 - N (maybe)
 - CH₄ - biogas
 - Heat
 - Hydraulic energy
 - Chemicals of interest (maybe)
 - Biosolids (N, P, organics)
 - Etc, etc, etc


Current HRSD R&D Efforts in BNR:

- Struvite avoidance and recovery (labor, energy, chemicals)
- Mainstream Deammonification & Nitritation-Denitritation (energy, chemicals, concrete)
- Supplemental carbon for denitrification (chemicals)
 - AOB conversion of methane to methanol
 - Reduced S compounds
 - Ethanol used for fuel blending
- Ammonia-based DO control systems (energy, chemicals, concrete)
- Cost-effective chemically enhanced primary treatment (chemicals, energy, concrete)
- Algae-based nutrient removal (chemicals, energy)
- Centrate deammonification = partial nitritation + anammox (chemicals, energy)
- Nitrite accum. and excessive chlorine demand (chemicals)
- IFAS process development and modeling (concrete, energy)
- Nitrification inhibition (concrete)
- Improvement of BNR process models (chemicals, energy, concrete)
- Organic nitrogen sources and fate (issue)
- Urine separation (???)

Global N Cycle – Impact of Haber-Bosch



History of Phosphorus-Based Fertilizers




Source: "The Story of Phosphorus: Global Security and Food For Thought", Cordell, et.al.
Global Environmental Change, Volume 19, Issue 2, May 2009

Modern Phosphorus Cycle



Global Distribution of Reserves Raises Questions


Global Reserves (15Gt: R/P=89)



R = Reserves
P = Production
...89 years of reserves

Disputed Phosphate Reserve Estimate

Global Reserves (60 Gt: R/P = 333)



R = Reserves
P = Production
...333 years of reserves

*IFDC Report –
September 2010*


A bit of background....

- Nitrification-Denitrification
- Biological P Removal


MLE Process (N Removal)



Nitrate/Internal Recycle (IMLR) = Nitrate Recycle (NRCY)




4-Stage Bardenpho (Better N Removal)




Phosphorus accumulating organisms (PAO's) Unique Anaerobic/Aerobic Metabolism


Anaerobic Conditions



Aerobic Conditions




Biological Phosphorus Removal (Bio-P)



Bio-P in A/O Process

A/O Process



ANA = Anaerobic

AER = Aerobic

Addition of an anaerobic selector...


Removal of P Through WAS

- Typical Mixed Liquor
 - 1.5 - 2% (P / MLVSS by weight)
- Bio-P Mixed Liquor
 - Up to 15-35% (P / MLVSS by weight)
 - 5 - 7% Typ.
- Lower SRT/MCRT = better Bio-P
 - Down to about 3 days

Six Key Considerations for Bio-P

- Input of sufficient rbCOD in the form of VFAs to the anaerobic zone.
- Minimization of oxygen and nitrate return to or presence in the anaerobic zone.
- Minimization of post-aerobic P release, either in an over-designed secondary anoxic zone or in the secondary clarifier.
- Operation at solids retention time (SRT) as low as possible (in excess of that required for nitrification).
- DO of ~2 mg/L at head of aerobic zone
- **Careful management of solids handling processes and recycle streams.**

Add Bio-P to MLE...




A²/O or Phoredox Process

ANA = Anaerobic


ANX = Anoxic

AER = Aerobic


Better P Removal (with Nitrification)



UCT Process




MUCT Process




VIP Process

The VIP® Process



- It was developed and patented by HRSD, VT, and CH2M Hill
- Biologically removes Phosphorus and Nitrogen
- Its free for any one to use...

5-Stage Bardenpho



Generally - “5-stage BNR”


Add second anoxic zone to a Bio-P processes
(for example VIP + 2, MUCT+2, A2O+2, etc)

HRSD Nansemond Plant

Nansemond Plant (pre 2008)




Phosphorus Profile



Values in mg/L TP

What is Struvite?



How Bad Can it Get?



Centrifuge Bowl Scoring




Pipe Restrictions

Nansemond Treatment Plant Upgrade




Process Flow Diagram

Nansemond Treatment Plant



What is the Ostara® Process



Ready to Use After Drying, No Post Processing




Pilot Testing

- >80 % phosphate recovery
- >42% ammonium recovery
- Higher P removal was achieved at lower pH conditions compared to previous studies
- Good Product quality
 - 2-4mm diameter pellets



Pilot Plant OP Performance



Average P removal 80%

Alternatives Cost Analysis

Cost Description	Do Nothing	Side Stream Chem Trmt	Ostara
Total Annual Savings	0	0	528,000
Total Annual Operating Costs	(392,000)	(429,000)	(91,000)
Net Annual Costs	(392,000)	(429,000)	437,000
Capital Costs			3,926,000
Net Present Worth @ 10 years	(3,027,000)	(3,313,000)	(552,000)
Net Present Worth @ 20 years	(4,885,000)	(5,346,000)	1,520,000

Summary of Benefits to Using Ostara Process

- Reduce recycle nutrient loads
- Reduce struvite scale formation
- Reduces phosphate concentration in biosolids
- Reduce sludge volumes (a little)
- Generate a high quality fertilizer that recovers costs
- Stabilize plant bio-P process

Reduced Costs & Improved Reliability




HRSD and Ostara's Agreement

- 10 year contract with Ostara to purchase all product produced at the facility with increases to purchase price based on the CPI.
- HRSD compensated for materials and operating costs.
- Ostara provides the equipment and process oversight.
- HRSD retains ownership of the building and equipment after contract expires.
- Ostara markets and distributes the fertilizer product under the name as CrystalGreen™. HRSD's name is not used on any packaging.


Struvite Recovery Facility Design Parameters

Parameter	Design	Units
Design Flow	110,000	GPD
NH ₄ Influent Concentration	650	mg/L as N
PO ₄ Influent Concentration	450	mg/L as P
Proposed No of Reactors	3	500 kg/day
Reactor PO ₄ Effluent Concentration	72	mg/L PO ₄ -P
PO ₄ Removal Efficiency	84	%
Mass of Phosphorous Removed	346	Lbs/day
Reactor NH ₄ Effluent Concentration	479	mg/L NH ₄ -N
NH ₄ Removal Efficiency	26	%
Mass of Nitrogen Removed	157	Lbs/day
Struvite Production Rate	501	Tons/year
Manpower Requirements (FTE)	0.5	5 days/wk

Struvite Facility Layout



Struvite Facility Cost



Struvite Facility Construction Schedule

- Proposal Submitted July 2009
- Commission Approval October 2009
- Contract Signed November 2009
- Operational May 2010
- Ribbon-cutting May 27, 2010



Complete Ostara System



**Crystal Green
Storage &
Bagging**

**Dewatering
Screen &
Dryer**

**Pearl
Reactors**

**Chemical
Storage &
Feed**

Struvite Recovery Facility Video

Fertilizer Product Locally Available




Available at White's Old Mill Garden Center in Chesapeake, VA

Struvite Recovery Facility Performance


P and N Recovery (mg/L)						
Period	PO4-P			NH3-N		
	Centrate	Ostrate	% Recov	Centrate	Ostrate	% Recov
Design	450	72	84	650	479	26
Dec 2011	440	44	90	787	603	23
YTD	354	44	87	509	385	27
12 Mon Avg	440	44	90	793	609	23

We are currently producing ~1.0 ton/day

Nansemond BNR Performance



Phosphorous Reduction in Solids




1. Locate facility as close as possible to dewatering facilities
2. Avoid pipe “traps” and standard elbows
3. Provide flush connections on all pipe runs
4. Feed CO₂ to centrate piping to control struvite
5. Construction sequencing of plant upgrade did impact performance
6. BNR and Digester operations are related to struvite recovery

Next Steps


- Install a permanent CO₂ feed system to inhibit struvite formation
- Evaluate WASSTRIP[®] process

Process Flow Diagram


Nansemond Treatment Plant



WASSTRIP Evaluation for Nansemond



WASSTRIP Impact – CWS Durham Plant



Sludge Sample Prior to WASSTRIP Implementation shows significant struvite crystals



~60 days after WASSTRIP Implementation, drastic reduction in struvite crystals

Imhoff cone with washed sludge shows drastic reduction in digester struvite formation



Sludge Sample **prior**
to WASSTRIP
Implementation with
15 ml/L of struvite
crystals




~60 days **after**
WASSTRIP
Implementation with
1 ml/L of struvite
crystals


HRSD Atlantic Treatment Plant




Current Atlantic Plant




Atlantic with WASSTRIP – No Ostara



OP - Batch Release Rate Measurements



Mg - Batch Release Rate Measurements



Conclusions

- Ostara process makes a clean and marketable product from centrate with minimal post processing
- Plant staff are enthusiastic
- WASSTRIP could eliminate struvite problems and struvite loss in dewatered biosolids

Questions?

Charles B. Bott

- cbott@hrsd.com
- 757-460-4228

