



The Metropolitan

*Water Reclamation District*

of Greater Chicago

**WELCOME  
TO THE JUNE EDITION  
OF THE 2017  
M&R SEMINAR SERIES**

# BEFORE WE BEGIN

- **SAFETY PRECAUTIONS**
  - PLEASE FOLLOW EXIT SIGN IN CASE OF EMERGENCY EVALUATION
  - AUTOMATED EXTERNAL DEFIBRILLATOR (AED) LOCATED OUTSIDE
- PLEASE SILENCE CELL PHONES OR SMART PHONES
- QUESTION AND ANSWER SESSION WILL FOLLOW PRESENTATION
- PLEASE FILL EVALUATION FORM
- SEMINAR SLIDES WILL BE POSTED ON MWRD WEBSITE (www.MWRD.org: Home Page ⇒ Reports ⇒ M&R Data and Reports ⇒ M&R Seminar Series ⇒ 2017 Seminar Series)
- STREAM VIDEO WILL BE AVAILABLE ON MWRD WEBSITE (www.MWRD.org: Home Page ⇒ MWRDGC RSS Feeds)

# CARLA D. DILLON, Ph.D., PE

- Current:*** Engineering Supervisor, Orange County Sanitation District (OCSD), Fountain Valley, California
- Experience:*** Lead teams responsible for research, interagency coordination, easements/right-of-way, annexations, sewer transfers, etc.; Planning Director of Emergency Operation Center, when active; As Engineer, Senior Engineer with OCSD, responsible for process engineering and optimization of plant odor control systems, optimized treatment processes to minimize odor generation, etc.; Prior to OCSD, as project engineer for Braun Intertec Corporation, 3M Company, CA Regional Water Quality Control Board
- Education:*** Ph.D. (Public Administration), University of La Verne, La Verne, CA  
M.S. (Civil Eng w/ minor in Public Health), Univ of Minnesota, Minneapolis, MN  
B.S (Envir Eng), California Polytechnic State University, San Luis Obispo, CA
- Professional:*** Licensed Professional Engineer in C;, Certified Water Treatment Operator; Committee Chair of WEF; Committee member of WE&RF
- Award:*** 2012 Jennings Randolph International Fellow, AWWA
- Volunteerism:*** City of Long Beach, Sustainable City Commission  
U.S. President's Volunteer Service Program



# Odor Control at the Orange County Sanitation District

**Dr. Carla D. Dillon, P.E.**  
**Engineering Supervisor**  
**Orange County Sanitation District**




# Outline

- OCSD Overview
- Collection System Odor Control
- WRRF/Plant Odor Control
- Complaint Process
- Odor Control Master Plan
- Other odor-related Research



# OCSD Service Area

- 396 miles of sewers
- 471 square miles
- 185 million gallons per day
- 2.6 million population
- 20 cities, 4 special districts
- 15  pumping stations
- 2  treatment plants



# Governance

## 25 Member Board

- 20 City Council Representatives
- 2 Sanitary District Representatives
- 2 Water District Representative
- 1 Member of the Orange County Board of Supervisors

## Committees

- Steering
- Administration
- Operations
- Legislative & Public Affairs



**Reclamation  
Plant No. 1  
Fountain Valley**




**Treatment  
Plant No. 2  
Huntington Beach**



# Collection System Odor Control




# Wastewater Collection System



Orange County Sanitation District (OCSD) Trunklines and Diversions



Pacific Quality Partners (PQP)



**OCSD Collections System**

- ▲ Lift or Pump Station
- Diversion Number Milewide
- Odor Control Dosing Location

**Plant No. 1 Trunklines**

- Green: East
- Brown: Newhope
- Blue: Baker-Main
- Purple: Sarti
- Light Blue: Sunflower
- Dark Blue: Santa Ana River Interceptor (linked to Plant 2 via Interplant)
- Orange: Knott (overlaid to Plant 1 and overflow to Plant 2 via Interplant)
- Pink: Baker (overlaid to Plant 1 via Knott)
- Red: OCSD-owned Local Sewers (in Baker-Main or Sunflower)

**Plant No. 2 Trunklines**

- Red: Interplant
- Green: Coast
- Pink: Miller-Holder
- Light Blue: Newport

Other symbols: Blue line for Ocean Outfalls, Blue dashed line for OCSD Service Area Perimeter, Yellow for County / Unincorporated.

Revision: 9/3/2016

- **Ferrous Chloride** – Used in Gravity Trunks
- **Magnesium Hydroxide** – Used in Force Mains
- **Calcium Nitrate** – Used in Force Mains
- **Caustic (Sodium Hydroxide)** – Used for batch dosing

OCSD Odor Control Chemical Dosing Locations



# Westside Pump Station (Los Alamitos)

YELLOWTAIL

Critical 1-hour response



# SARI Facilities in Yorba Linda

SARI Gate

Yorba Linda Spur Odor Control

SAVI Ranch



Santa Ana River

SARI Metering Station

Gypsum Canyon

# Collection System Dosing


- Multi-chemical
  - Iron
  - Magnesium Hydroxide
  - Calcium Nitrate
  - Sodium Hydroxide
- Quality assurance of chemicals
- Real time testing
- Dynamic program to allow for quick change
- $\leq 25$  ppm  $H_2S$  headspace
- $\leq 0.5$  ppm dissolved sulfides



# Water Resource Recovery Facilities Odor Control




# Orange County Sanitation District Wastewater Treatment Process




## 1. METERING AND DIVERSION

Wastewater enters our plant at 2.5 - 5 mph through pipes up to 10 feet in diameter. High tech equipment monitors the temperature, pH, conductivity, and flow of the incoming wastewater.




## 5. SECONDARY TREATMENT

Trickling filters and aeration basins are used to further clean the water. In trickling filters the water is sprayed over a honeycomb type material upon which aerobic bacteria grow. As the water trickles down, the microorganisms consume the solids that were not removed through primary treatment. Aeration tanks use a combination of oxygen and microorganisms, (activated sludge) that consume the remaining organic solids. Treated water is then sent to the Orange County Water District for recycling, or discharged into the ocean.



## 2. PRELIMINARY TREATMENT

Raw sewage passes through bar screens that trap large items like rags that cannot be recycled. Materials like egg shells and coffee grounds are then removed through the grit chamber that uses high pressure air to separate the gritty material.



## 3. AIR SCRUBBER

Hydrogen Sulfide (foul air) is captured throughout the process and funneled into large silos. It passes through a plastic medium and mixes with caustic soda and bleach. Causing the odorous compounds to be neutralized.




## 4. PRIMARY TREATMENT

Primary clarifiers or settling basins, slow the water down to let the solids that are within the water settle out, separate and float to the surface. Scrapper arms that move along the top and bottom remove up to 80% of the solids. Solids are then sent to digesters for processing.



## 6. BIOSOLIDS

Solids captured from primary and secondary processes are batch loaded into anaerobic digesters where they are heated to about 98 degrees and treated for 18-21 days. They enter de-watering where water is squeezed out using belt presses. The nutrient rich biosolids are trucked off to farms where they are recycled for direct land application, and composting. The digestion process produces methane gas.



## 7. CENTRAL GENERATION

Methane gas that is captured from digesters is compressed and used to fuel engine-generators that produce electricity, supplying about 60% of our energy needs.



# WRRF Odor Control – Plant No. 1

Process Area	Existing Treatment
Headworks	Packed bed chemical scrubbers operated in caustic-bleach mode plus trunkline roughing biofilter
Primaries	Packed bed chemical scrubbers operated in bleach-only mode



# WRRF Odor Control – Plant No. 1

Process Area	Existing Treatment
Activated Sludge (AS-1 & AS-2)	None
Trickling Filters	None
DAFT	Packed bed chemical scrubbers operated with plant water only



# WRRF Odor Control – Plant No. 1

Process Area	Existing Treatment
Truckloading/Dewatering	Packed bed chemical scrubbers operated with plant water only
Wastehauler Station	Biorem Biofilter (demolished)



# WRRF Odor Control – Plant No. 2

Plant 2	Existing Treatment
Headworks	2-sec. EBGRT bioscrubber (recirculating) followed by chemical scrubbers operated in caustic-bleach mode plus trunkline roughing bioscrubbers
Primaries (NSC & SSC)	Packed bed chemical scrubbers operated in bleach-only mode



# WRRF Odor Control – Plant No. 2



Plant 2	Existing Treatment
DAFTs	Biofilter
Trickling Filters	Carbon
Trickling Filters Contact Basins	None
Truckloading	None



# Odors

- Compliance
- Complaint Process
- Internal Goals






# SCAQMD Rule 402 – Nuisance

Prohibits discharge from any source  
air contaminants which cause nuisance  
or annoyance or which endanger the comfort, health  
or safety of any number of persons or the public



# All Complaints Processed Online

## Call Center



The screenshot shows a web application interface for a Call Center. The top navigation bar includes links for Home, Reports, Apps, Admin Services, and Engineering. The left sidebar contains a navigation menu with the following items: View All Site Content, Call Center (highlighted), New Complaint (circled in red), New Customers, Pending Approval / Review Tasks, Customer List, Lists, Documents, and Recycle Bin. The main content area displays the breadcrumb path Home > Apps > Call Center. Below this, there are two sections: "Open Complaints" and "Supervisor Approval / Review Tasks". Each section has a table with columns for Type, Name, Customer, and Incident, and a note stating "To create a new item, click 'New' or 'Add'".

- Logged in by anyone receiving complaint into call center
- Everyone shares and tracks information




# Prior Goals for Odor Control

- Design all new projects to retain odor within property boundaries (10 D/T)
- No off-site odors from WRRF's during normal operations
- 12 complaints per year in Collection System
- Respond to WRRF odor complaints within 1 hour
- Respond to Collection System odor complaints within 1 day
- Respond to spills within 1 hour



# Odor Complaints



# Odor Control Master Plan

- 2003 Master Plan – H<sub>2</sub>S based
- 2008 Master Plan – D/T based
- 2017 Master Plan –




# 2017 Odor Control Master Plan

- Why initiate it
- Monitor
  - Chemical
  - OPM
  - D/T
- Pilot
- Model
- Recommended treatment




# Previous Goal



# Odor Impact Modeling

2008 Master Plan  
Approach



# Master Plan Criteria

- Determine “most detected” odorant removal efficiency by OCSD treatment systems
- Determine which treatment technology is more effective at removing the combination of odorants identified based on three nuisance criteria:
  1. Current system (do nothing)
  2. Best single stage system
  3. Best multiple stage system
- Determine the odor impact at the fence line for each of the above nuisance criteria, which will become the new Level of Service options
- Determine costs associated with each LOS





**LEGEND**

→ FLOW DIRECTION  
 M METER  
 RCP PUMP  
 SD SCREEN  
 W VALVE

**PROCESS WATER**

BW - BACKWASH (GAP)  
 SWS - BACKWASH WASTE (WF)  
 CSW - CLEAN  
 INTDI - INTERPLANT  
 MFF - MICROFILTRATION FEED  
 ML - MIXED LIQUOR  
 OVF - OVERTFLOW  
 PE - PRIMARY EFFLUENT  
 PE - PRIMARY EFFLUENT  
 RCO - REVERSE OSMOSIS CONCENTRATE  
 RT - RAW SEWAGE  
 SE - SECONDARY EFFLUENT  
 TFE - TRICKLING FILTER EFFLUENT  
 TFE - TRICKLING FILTER EFFLUENT  
 WSS - WASTE STREAM

**STRUCTURE**

CS - DISTRIBUTION STRUCTURE  
 H - HEADWORKS  
 JB - JUNCTION BOX  
 M&S - METERING AND SAMPLING  
 PS - POWER BUILDING  
 PDD - PRIMARY EFFLUENT DISTRIBUTION BOX  
 PJD - PRIMARY EFFLUENT JUNCTION BOX  
 PPS - PRIMARY EFFLUENT PUMP STATION  
 PPS - PUMP STATION  
 PPS - PLANT WATER PUMP STATION  
 PALS - RETURN ACTIVATED SLUDGE  
 SAR - SANTA ANA RIVER DISCHARGE  
 SC - SECONDARY CLARIFIER  
 SEJ - SECONDARY EFFLUENT JUNCTION BOX  
 TEB - TRICKLING FILTER EFFLUENT BOX  
 TFE - TRICKLING FILTER EFFLUENT BOX  
 TFS - TRICKLING FILTER PUMP STATION  
 TSC - TRICKLING FILTER SECONDARY CLARIFIER  
 WSSPS - WASTE SEW STREAM PUMP STATION

PIPE SIZE  
 PROCESS

**LEGEND**


— Foul Air Duct  
 — Foul Air Plenum  
 ● ● ● Roughing, Scrubber, Stack  
 ■ Diffuse Source of Odors






- LEGEND**
- FLOW DIRECTION
  - ⊙ METER
  - ⊠ PUMP
  - ⊡ SCREEN
  - ⊞ VALVE
- PROCESS WATER**
- DR - DRAIN
  - INT - INTERPLANT
  - ML - MIXED LIQUOR
  - OUT - OUTFALL
  - OVF - OVERFLOW
  - PE - PRIMARY EFFLUENT
  - PI - PRIMARY INFILTRANT
  - ROC - RETURNED ACTIVATED SLUDGE CONCENTRATE
  - RS - RAW SEWAGE
  - SE - SECONDARY EFFLUENT
  - TRE - TRICKLING FILTER EFFLUENT
  - TRE - TRICKLING FILTER SECONDARY EFFLUENT
  - WS - WASTE SIDE STREAM
- STRUCTURES**
- BLD - BUILDING
  - CHEM - CHEMICAL
  - DS - DISTRIBUTION STRUCTURE
  - EPFA - EFFLUENT PUMP STATION ANNEX
  - FAC - FACILITY
  - FR - FROSTER/ROOSTER
  - HW - HEADWORKS
  - IB - INFLUENT DIVERSION BOX
  - JB - JUNCTION BOX
  - MAD - MEASURING AND DIVERSION
  - MH - MANHOLE
  - PH - PUMP HOUSE
  - PEOD - PRIMARY EFFLUENT DISTRIBUTION BOX
  - PEJB - PRIMARY EFFLUENT JUNCTION BOX
  - PEPS - PRIMARY EFFLUENT PUMP STATION
  - PIAB - PRIMARY INFILTRANT JUNCTION BOX
  - PS - PUMP STATION
  - PMWD - PLANT WATER DISTRIBUTION BOX
  - PMWP - PLANT WATER PUMP STATION
  - RAS - RETURN ACTIVATED SLUDGE
  - RSD - RETURN SECONDARY SLUDGE
  - SAR - SANTA ANA RIVER DISCHARGE
  - SC - SECONDARY CLARIFIER
  - SEJB - SECONDARY EFFLUENT JUNCTION BOX
  - SLB - SCREEN LOADING BUILDING
  - TREB - TRICKLING FILTER EFFLUENT BOX
  - TREPS - TRICKLING FILTER PUMP STATION
  - TRESE - TRICKLING FILTER SECONDARY CLARIFIER
  - WSPPS - WASTE SIDE STREAM PUMP STATION
- PIPE SIDE**
- 60" SE
  - 60" SE

- LEGEND**
- Foul Air Duct
  - Foul Air Plenum
  - ● ● Roughing, Scrubber, Stack
  - Diffuse Source of Odors




# Limitations of Analytical Methods



# Odorants Detected at OCSD

Odorant	Odor Threshold (ppbV)	Odor Description	Method Reporting Limit (ppbV)
Acetic Acid	1,019	Sour, Vinegar	8.0 – 4.0
Butyric Acid	0.33	Sour, Sweaty	0.68 – 0.34
Ammonia	38.28	Pungent, Irritating	0.52 – 0.26
Trimethyl Amine	0.33	Fishy, Pungent	4.2 – 2.1
Skatole	0.000075	Fecal, Sewery	
2-Methyl Isoborneol	0.013	Earthy/Musty	
Methyl Mercaptan	0.020	Sulfidy, Rotten Vegetables	5.0
Carbonyl Sulfide	10.32	Sulfidy	5.0
Dimethyl Trisulfide	1.2	Rotten Garlic	2.5
Dimethyl Disulfide	0.026	Rotten Garlic	2.5
Dimethyl Sulfide	0.99	Canned Corn, Cabbage	5.0
Hydrogen Sulfide	0.50	Rotten Eggs	5.0

# Determining Odors



## Methods:

- Analytical
  - Amines
  - Carboxylic Acids
  - Reduced Sulfur
- Sensorial
  - D/T
  - OPM
    - GC/MS
    - GC/MS sniff

## Wastewater Odor




# Odor Control Master Plan

## Interim Milestones


- Develop standard analytical protocols for:
  - 2-Methyl Isoborneol (Earthy/Musty odors)
  - Skatole (Fecal odors) to determine its presence at all process areas
- Develop the Weber-Fechner curves for all 7 “most detectable” odorants:
  - Hydrogen Sulfide (H<sub>2</sub>S) – Rotten Egg
  - Methyl Mercaptan (MM) – Rotten Vegetable
  - Dimethyl Sulfide (DMS) – Canned Corn
  - Dimethyl Disulfide (DMDS) - Rotten Garlic
  - Ammonia - Pungent
  - 2- Methyl Isoborneol (MIB) - Musty
  - 2-Isopropyl-3Methoxypyrazine (IPMP) - Musty
  - Indole - Fecal
  - Skatole - Fecal



# Relating Odor Intensity with Concentration



## Weber-Fechner Curves for "Most Detectable" Odorants



# Existing Average Odorant Removal Rates

Treatment System	H <sub>2</sub> S (%)	MM (%)	DMS (%)	DMDS (%)	Ammonia (%)	MIB (%)	IPMP (%)	Skatole (%)	Indole (%)
<b>PLANT 1 Treatment Systems</b>									
Wastehauler Biofilter	99	99	24	0	0	-53	-53	78	78
Headworks Scrubbers	91	60	40	42	0	-30	-30	50	50
Primary Scrubbers	92	60	60	42	20	40	40	30	30
DAFT Scrubbers	0	0	0	0	0	0	0	0	0
Dewatering/Truckloading Scrubbers	0	0	0	0	0	0	0	0	0
<b>PLANT 2 Treatment Systems</b>									
Headworks Scrubbers	98	97	70	94	0	72	72	84	84
Primary Scrubbers North	85	64	27	0	20 <sup>b</sup>	40	40	60	60
Primary Scrubbers South	85	64	27	0	20 <sup>b</sup>	40	40	60	60
Trickling Filter Scrubbers	95	97	42	-158	0	65	65	75	75
DAFT Biofilter	90 <sup>a</sup>	80 <sup>a</sup>	50 <sup>a</sup>	0	20 <sup>a</sup>	0	0	43.5	43.5
Dewatering Scrubbers	0	0	0	0	0	0	0	0	0

## Notes:

Negative numbers represent odor generation and are likely because of odorant transformation or conversion within treatment beds


All removal rates are calculated strictly from treatment units and are not calculated based on receptor concentrations or fence line concentrations

<sup>a</sup> Representative because no data provided.


<sup>b</sup> Since nondetectable, used Plant No. 1 primary scrubber removal rate.

# Current Emission Proportions


## Plant 1 Methyl Mercaptan




## Plant 2 Methyl Mercaptan



## Plant 1 Hydrogen Sulfide



## Plant 2 Hydrogen Sulfide



# Pilot Testing Research

- Test additional treatment systems and/or pilot treatment unit to determine removal efficiency of “most detected”:
  - Chemical Scrubbers (using different chemical reactants)
  - Biofilters (using different natural media and EBRT’s)
  - Biotowers (using different synthetic media and EBRT’s)
  - Adsorbents (using different media)
  - Reaction Chambers (using ionized air, photo catalytic oxidation, ozone generators, etc.)
- Summarize results in a matrix with existing industry knowledge



# Pilot Unit



Foam Cubes



Matala & Foam



Coated Pumice



Seashells




Lava Rock



Coal, Coconut,  
Permanganate  
Activated Carbon




Figure ES-1. Odorant Nuisance Impacts, Baseline Existing Condition – Plant No. 1



# Odorants Recommended for Mitigation

Plant No. 1 Summary of Sources Recommended for Mitigation				
	H <sub>2</sub> S	MM	Musty	Fecal
Headworks Scrubbers	✓	✓		
Primary Scrubbers	✓	✓		
DAFT Scrubbers		✓		
Dewatering/Truckloading Scrubbers		✓		
Activated Sludge Basin Stacks		✓		
Activated Sludge Basins	✓	✓		✓
Trickling Filter Open Tops	✓	✓	✓	
Cake Truck Loading Door		✓		
Wastehauler Station	✓			





# Odorants Recommended for Mitigation

Plant No. 2 Summary of Sources Recommended for Mitigation			
	H <sub>2</sub> S	MM	Musty
Headworks Scrubbers	✓	✓	
Primary Scrubbers North	✓	✓	
Primary Scrubbers South	✓	✓	
Trickling Filter Contact Basins		✓	✓
DAFT Biofilter		✓	
Truckloading Silos Fans		✓	
Cake Truck Loading Door		✓	


Process Area	Recommendation
<b>Plant 1</b>	
Headworks	45-sec. EBGRT biofilter (lava rock or engineered media)
Primaries	45-sec. EBGRT biofilter (lava rock or engineered media)
DAFT	Optimize existing chemical scrubbers operated in caustic-bleach mode
Truckloading/Dewatering	Optimize existing chemical scrubbers operated in caustic-bleach mode
Activated Sludge (AS-1 & AS-2)	Cover reactor basins and withdraw foul air through new chemical scrubbers
Trickling Filters	Cover towers and withdraw foul air through new chemical scrubbers operated in caustic-bleach mode
<b>Plant 2</b>	
Headworks	45-sec. EBGRT biofilter (lava rock or engineered media)
Primaries (NSC & SSC)	New chemical scrubbers operated in caustic-bleach mode
Trickling Filters Contact Basins	Cover reactor basins and withdraw foul air through new chemical scrubbers operated in caustic-bleach mode
Truckloading	Withdraw foul air through new chemical scrubbers operated in caustic-bleach mode

# OCSD Research


Business opportunity • Partnerships  
New technology • Lower cost • Environmental stewardship





# Current Digester Gas Treatment




# Alternative Digester Gas Treatment



**Primary  
Treatment**




**Digesters**



**Central Power  
Generation  
System Engines**

**Electricity**



**Water**

**Digester  
Gas**




# Why It Works

Compound	Solubility <sup>(1)</sup>	Ratio
CH <sub>4</sub> (methane)	4	-
H <sub>2</sub> S (hydrogen sulfide)	300	73 : 1
CO <sub>2</sub> (carbon dioxide)	256	64 : 1

(1) ft<sup>3</sup> gas per 1000 gal water




# Alternative Digester Gas Treatment



# Next Steps/Recommendation: Large-Scale Pilot Tests

- Construct instrumented test equipment (2" dia. venturi; 500 gal tank)
- Optimize process performance
- Reduce water usage
- Minimize methane loss
- Respond to changes in digester gas flow



# Questions



**Carla Dillon**  
**Cdillon@ocsd.com**

