

*Protecting Our Water Environment*




**Metropolitan Water Reclamation District of Greater Chicago**

**Moving Towards Disinfection at the District's  
Terrence J. O'Brien and Calumet Water  
Reclamation Plants**

**Edward C. Brosius, P.E.**  
*Supervising Civil Engineer*

# Water Resources



■ Oceans  
(Salinity > 35,000 ppm)


■ Ice at the Polar Caps

■ Atmosphere

■ Rivers and Lakes

■ Groundwater Aquifers  
(A half at depth > 2,600 ft)

# Chicago Waterway System












NEW IRIS  
CREW



# Number of Fish Species Below the Outfalls of Three MWRD Water Reclamation Plants



# Use Attainability Analysis (UAA) for Chicago Area Waterways (CAWs) 2002 to ?



# Use Attainability Analysis (UAA) for Chicago Area Waterways (CAWs)

- Recreational Use Designation (Disinfection)
- Aquatic Life Use Designation (Thermal Pollution) (Dissolved Oxygen)



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
WASHINGTON, D.C. 20460

MAY 11 2011

OFFICE OF WATER

Lisa Bonnett  
Interim Director  
Illinois Environmental Protection Agency  
1021 North Grand Avenue East  
Springfield, Illinois 62702

Dear Ms. Bonnett:

During the past 25 years, the Chicago Area Waterway System (CAWS) has been transformed into a valuable recreational asset that citizens increasingly use for boating, canoeing, kayaking, jet and water skiing, tubing and swimming. The State of Illinois is long overdue on updating its water quality standards to provide the Clean Water Act (CWA) protections that must accompany this transformation. Consequently, the U.S. Environmental Protection Agency has determined that new or revised water quality standards that protect recreation in and on the water are necessary for certain segments of the CAWS. EPA expects Illinois to expeditiously adopt new or revised water quality standards consistent with this determination. If Illinois fails to do so, EPA will promptly do so itself. In either event, to attain those standards, the Metropolitan Water Reclamation District of Greater Chicago (MWRDGC) would likely be required to disinfect discharges from its North Side and Calumet Water Reclamation Plants.

Specifically, EPA has determined that new or revised use designations that provide for recreation in and on the water are necessary for the following segments of the CAWS (hereafter, "the relevant CAWS segments") that are currently designated as Secondary Contact Waters under 35 Ill. Adm. Code 303.441:

- Calumet-Sag Channel;
- Little Calumet River: from its junction with the Grand Calumet River to the Calumet-Sag Channel;
- South Branch of the Chicago River;
- North Branch of the Chicago River from its confluence with the North Shore Channel to its confluence with the South Branch; and
- North Shore Channel, excluding the segment extending from the North Side Sewage Treatment Works to Lake Michigan.

These segments are shown below.



146 3 P.M. 7-25-94  
RioHo Bld.





# Estimated Timelines for Implementation of UV Disinfection without Filtration<sup>1</sup>

	Stickney WRP <sup>2</sup>	North Side WRP	Calumet WRP
Procurement of Professional Services	0.5 years	0.5 years	0.5 years
Investigative Phase	3 years	3 years	3 years
Program Development and Conceptual Design	1.5 years	1.5 years	1.5 years
Final Design	2 years	1.5 years	1.5 years
Construction	4 years	2.5 years	2.5 years
<b>Total</b>	<b>11 years</b>	<b>9 years</b>	<b>9 years</b>

2020

2020

<sup>1</sup> The need for Filtration will be assessed through water analysis and pilot testing

<sup>2</sup> The implementation schedule for SWRP is longer than NSWRP and CWRP because the SWRP facilities are both larger, and involve more extensive civil/site work related to the effluent conduits and outfall



Metropolitan Water Reclamation District of Greater Chicago

**Timetable for Implementation of Disinfection  
at the North Side and Calumet Water Reclamation Plants**

Phase	Costs*	Schedule
I. INVESTIGATION PHASE	Analytical tests and equipment: \$350,000 Transmittance meters: \$40,000 Site visits: <u>\$10,000</u> Total: \$400,000	9/2011 to 3/2012
II. DESIGN PHASE	Design Engineering: \$34,000,000	4/2012 to 3/2013
III. CONSTRUCTION PHASE	Construction Cost: \$240,000,000 Post-Award Engineering: <u>\$12,000,000</u> Total: \$252,000,000	Advertise, Bid, Award: 4/2013 to 10/2013  Construction: 11/2013 to 11/2015
IV. START UP AND OPERATION PHASE	Annual Operation Cost: \$10,100,000	12/2015 and on

6 Months

1 Year

2 Years

\*All costs are in year 2011 dollars



Ab dem 29. April 2004 überall im Handel auf DVD erhältlich.

# THE ULTIMATE A TEAM



© 2004 Universal Studios. Alle Rechte vorbehalten.

# Disinfection Task Force

- Edward Podczerwinski
- Beata Busza (Engineering)
- Judith Moran-Andrews
- Doris Bernstein (M&R)
- Joe Ford
- Brian Perkovich (M&O)

# 7 WATER RECLAMATION PLANTS



Stickney	1200 MGD
Calumet	354 MGD
North Side	333 MGD
Kirie *	72 MGD
Egan *	30 MGD
Hanover Park *	12 MGD
Lemont	3 MGD

\* Disinfection Facilities

# Evaluation of Disinfection Technologies for the Calumet and O'Brien Water Reclamation Plants

Technical Memorandum 1  
Date: December 12, 2011

Subject: Available Disinfection Technologies  
and Short List of Technologies for Further  
Evaluation

# Evaluation of Disinfection Technologies for the Calumet and O'Brien Water Reclamation Plants

Technical Memorandum 2  
Date: December 21, 2011

Subject: Historic Plant Flows, Water  
Quality Data, and Other Test Results

# Evaluation of Disinfection Technologies for the Calumet and O'Brien Water Reclamation Plants

Technical Memorandum 3

Date: February 17, 2012

Subject: Evaluation Matrix Ratings and  
Results

# Evaluation of Disinfection Technologies for the Calumet and O'Brien Water Reclamation Plants

Technical Memorandum 4  
Date: May 4, 2012

Subject: Design Criteria and Conceptual  
Design for Selected Disinfection  
Technologies at the Calumet and North  
Side Water Reclamation Plants

# Task Force Recommendations



- O'Brien WRP - Ultraviolet (UV) Disinfection
- Calumet WRP – Chlorine Disinfection/De-Chlorination
- Triple Bottom Line Approach

# O'Brien WRP Design Parameters

- Flow Rates
  - Average Flow: 240 MGD
  - Maximum Flow: 450 MGD
- Disinfection Standard (Fecal Coliform)
  - Monthly Geometric Mean: 200 CFU/100 mL
  - Less Than 10% Greater Than 400 CFU/100 mL
  - Disinfection Season: March 1<sup>st</sup> - November 30<sup>th</sup>
- Disinfection Technology

## ULTRAVIOLET IRRADIATION

USING LOW PRESSURE  
HIGH OUTPUT LAMPS



# Calumet WRP Design Parameters

- Flow Rates
  - Average Flow: 270 MGD
  - Maximum Flow: 430 MGD
- Disinfection Standard (Fecal Coliform)
  - Monthly Geometric Mean: 200 CFU/100 mL
  - Less Than 10% Greater Than 400 CFU/100 mL
  - Disinfection Season: March 1<sup>st</sup> - November 30<sup>th</sup>
- Disinfection Technology

## CHLORINATION



## /DE-CHLORINATION

## WITH PURCHASED CHEMICALS



$\text{NaOCl}$

$\text{NaHSO}_3$

## Consolidated Consultant Interviews

### Monday October 10, 2011

#### Consultant

9:00 a.m.-10:00 a.m.

Greeley & Hansen LLP

11:00 a.m.-12:00 noon

Black & Veatch Corporation

2:00 p.m.-3:00 p.m.

~~Malcolm Pirnie, Inc.~~

### Tuesday October 11, 2011

#### Consultant

9:00 a.m.-10:00 a.m.

MWH Americas, Inc.

11:00 a.m.-12:00 noon

Camp Dresser and McKee, Inc.

2:00 p.m.-3:00 p.m.

HDR Engineering, Inc.

### Wednesday October 12, 2011

#### Consultant

9:00 a.m.-10:00 a.m.

AECOM

11:00 a.m.-12:00 noon

CH2M Hill, Inc.



How the customer explained it



How the project leader understood it




How the engineer designed it




How the programmer wrote it



How the sales executive described it




How the project was documented



What operations installed



How the customer was billed



How the helpdesk supported it



What the customer really needed



# OWRP Project Timeline

- Chose Greeley and Hansen as Consultant
- Project Design Kick-off - April 2012
- Preliminary Design - June 2012
- 60% Design - November 2012
- Final Design - March 2013
- Construction Start - Fall 2013
- System On-line – December 2015

# Terrence J. O'Brien WRP

- Commissioned in 1928
- Located in Skokie, Illinois
- Serves over 1.3 million people in 141 square miles
- Conventional activated sludge plant
- Effluent from final settling tanks discharges into the North Shore Channel
- Plant Flow Rates
  - Average: 240 mgd
  - Design: 333 mgd
  - Total Permitted Maximum Flow: 450 mgd
  - Peak Hydraulic Capacity: 530 mgd

# Preliminary Design

- UV Dosage
  - 10 States Standards
    - UV Dose of 30 mJ/cm<sup>2</sup>
  - Illinois EPA
    - UV Dose of 40 mJ/cm<sup>2</sup>
  - 40 mJ/cm<sup>2</sup> dose selected

# UV Doses

- Amount of energy needed to inactivate microorganisms
- Dosage units are in terms of the energy reaching the organism multiplied by the organism's contact time in the UV irradiation field
- Units:  $\mu\text{J}/\text{cm}^2$ , or  $\mu\text{Ws}/\text{cm}^2$ , or  $\text{J}/\text{m}^2$

# UV Transmittance

## Typical UVT Ranges:

Type of Wastewater	UV% Transmittance [% , cm <sup>-1</sup> ]
Primary effluent	28 – 50
Secondary effluent	45 – 70
Nitrified effluent	56 – 79
Filtered nitrified effluent	56 – 79
Microfiltration and MBR	79 – 91
Reverse Osmosis	89 – 98

## UV transmittance:

- Defined as the fraction of incident light at 254nm, remaining, after passage through a 1.0 cm pathlength of a sample of the water
- Measured in percent

# Collimated Beam Testing

- UV Design Guidance Manual  
Recommended Test Procedure:
  - Samples are subjected to UV light through the testing apparatus.
  - Fecal coliform concentration is measured before and after the test.
  - UV Dose delivered to the sample is then calculated based on the factors of the apparatus setup, UV intensity, and exposure time.


# Collimated Beam Testing Apparatus



# OWRP - Collimated Beam Testing

- Samples were collected over 12 month period and at a variety of flow rates.
  - Dry, average, and wet weather conditions were sampled.
  - Various UVT levels.
- Various dosages were tested to determine the dosage required to meet regulatory requirements;
  - Both fecal coliform and e. coli limits were analyzed.


# Collimated Beam Test Results




# Results of Collimated Beam Testing

- UV Dose of  $15\text{mJ}/\text{cm}^2$  worked effectively to keep bacteria counts under the desired limits.
- UV Dose of  $10\text{ mJ}/\text{cm}^2$  worked effectively on over 85% of the samples to keep bacteria counts below the desired limits.
- What does this mean?
  - Using a factor of safety of 2 yields a Design UV dose of  $30\text{ mJ}/\text{cm}^2$ .

# UV Dose Curves



# UV Dose Curves at Lower UVT




# Basis of Design


	<b>Value</b>	<b>Unit</b>
Total Permitted Maximum Flow	450	MGD
Total Average Flow	240	MGD
Number of Channels	7	
Peak Flow per Channel	75.7	MGD
Minimum UVT	65	%
Minimum UV Dose at Total Peak Flow	30	mJ/cm <sup>2</sup>
End of Lamp Life (EOLL)	0.86	
Fouling Factor (FF)	0.95	
Fecal Coliform - 30-day Geo-mean Monthly	200	cfu/100 mL
Maximum	400	cfu/100 mL
- Less than 10% Above		
Lamp Life Warranty	15,000	hours

# Site Plan - OWRP


UV Disinfection Building



# Proposed Facility Site Plan



# TrojanUV Signa System



# TrojanUV Signa Maintenance




Mobile Platform for Maintenance Access


Routine Maintenance  
With Banks in  
Lowered Position

Periodic Maintenance  
With Banks in Raised  
Position

# UV Building Overall Plan



# Typical OWRP Flows



# Hydraulic Profile Existing Conditions





TABLE 1 - W/NORTH SHORE CHANNEL @ EL +2.0

LOCATION	530	450	240
FINAL SETTLING TANK (WSE IN FURTHEST POINT OF EFFLUENT TROUGH)	EL+19.08	EL+18.95	EL+18.42

**NOTES:**

- MAX ELEVATION AS PROVIDED BY MWRDGC
- WATER SURFACE EL BASED ON LONGEST FLOW PATH FROM NORTH SHORE CHANNEL TO FINAL SETTLING TANK #10 OF BATTERY D.
- FLows TO BATTERY A THROUGH D BASED ON FOLLOWING SPLIT:
  - NORMAL FLOW (230 MGD): 25% TO EACH BATTERY
  - WET WEATHER FLOW (450 MGD): A=22%, B=24%, (530 MGD): C=22%, D=32%

# Seven UV Channel Configuration CFD Modeling



# Flow Conditions

Total Flow (MGD)	Number of Channels in Service	Flow Per Channel (MGD)	UV Effluent Fixed Weir Elev. (ft)	Channels in Service						
				No. 1	No. 2	No. 3	No. 4	No. 5	No. 6	No. 7
530	7	75.7	+8.25	X	X	X	X	X	X	X
450	6	75.0	+8.25	X	X	X	X	X	X	
240	4	60.0	+8.61	X	X	X	X			
180	3	60.0	+8.61	X	X	X				


# Operations and Control

Condition	Influent Gate	Weir Gate	Drain Gate	Channel Water
Active	Open <sup>1</sup>	Modulating	Closed	Full
Ready	Open <sup>1</sup>	Raised	Closed	Full
Standby	Closed	Raised	Closed <sup>2</sup>	Empty


- 
1. Normally, 100% open, but optionally less than 100% may be selected for better flow distribution.
  2. When transitioning to Standby, drain gates to be open for preset period of time, then will close.



# Ready Gate Position



# Active Gate Position





# CWRP Project Timeline

- Chose CH2M HILL Engineers, Inc.
- Project Design Kick-off - April 2012
- Preliminary Design - June 2012
- 60% Design - November 2012
- Final Design - March 2013
- Construction Start - Fall 2013
- System On-line – December 2015

# About the Calumet WRP

- 480 mgd peak hydraulic flow, 270 mgd average
- Primary and secondary treatment
- High-quality secondary effluent, with avg TSS of 5 mg/L
- Nitrification year-round, with average ammonia concentration of 0.21 mg/L as N
- Existing chlorine contact basin constructed in 1960s
- Chlorine is the most cost-effective option due to the existing CCB



# Bench-Scale Testing Program


- *Testing conducted at ASL in Corvallis, OR*

TABLE 1  
Calumet Water Reclamation Plant Secondary Effluent  
Water Quality, April 30 and July 19, 2012

General Chemistry Analysis		Round 1 (4/30/12) Result	Round 2 (7/19/12) Result
Alkalinity	mg/L as CaCO <sub>3</sub>	143	51.3
Ammonia	mg/L as N	<0.10	0.95
Nitrate	mg/L as N	13.0	12.0
Nitrite	mg/L as N	0.15	0.4
Phosphate, Ortho	mg/L as P	3.3	4.4
Phosphate, Total	mg/L as P	3.5	4.8
pH	units	7.16	7.37
TSS	mg/L	<2.0	10.0
Turbidity	NTU	2.2	7.5
TOC	mg/L	8.6	9.1
UV-254 Transmittance (UVT)	%	70.8	69.5
Fecal Coliform (geometric mean)	CFU/100 mL	35,537	21,799
E. Coli (geometric mean)	CFU/100 mL	2,974	11,730
Enterococci (geometric mean)	CFU/100 mL	N/A	2,044

# Chlorine Demand Test Results, Round 1


FIGURE 1  
Chlorine Demand in Calumet WRP Secondary Effluent



# Chlorine Demand Test Results, Round 2

FIGURE 2


Chlorine Demand in Calumet WRP Secondary Effluent




# Chlorine Is an Effective Disinfectant for Calumet

- Adequate chlorine dose and contact time are required*

Fecal Coliform




Fecal Coliform



# Sodium Bisulfite Will Be Used for Dechlorination

- Sodium bisulfite quenches remaining chlorine residual present to protect aquatic life
- Sodium bisulfite is effective in Calumet effluent




# Design Requirements for the Disinfection Facilities

- 10-State Standards and Illinois Administrative Code (Title 35) require:
  - Chlorine Design Dose  $\geq 6$  mg/L for nitrified secondary effluent, 8 mg/L for activated sludge effluent
  - Chlorine Contact Time  $\geq 15$  minutes (after full mixing)
  - Sodium Bisulfite Dose  $\geq$  theoretical dose + 10% excess
  - Dechlorination Contact Time  $\geq 30$  seconds (including mixing)

# Basis of Design – Chemical Systems

- Hypochlorite and bisulfite in one “Disinfection Chemical Building”
- 7- days storage of each chemical at average conditions 4- days Max flow conditions
- Enclosed building provides:
  - Greater security
  - Minimal degradation of chemical inventory
  - Ability to store chemicals through winter

# Basis of Design – Chemical Diffuser



Proposed Diffuser Assembly  
(inset - nozzle spray)


Proposed chemical diffuser system similar to systems used in the past, however, design improvements include:

- Smaller orifice holes to create backpressure and improve flow distribution
- Spray nozzles to improve coverage and initial mixing
- Isolation valves to maintain reasonable pressure and distribution at lower flows

# Basis of Design – Chlorine Contact Basin (CCB)

- Existing CCB:
  - Provides 15 minutes of contact time
  - Requires improvements to reduce headloss
  - Needs extensive concrete rehabilitation for use in current configuration





**WATER SERVICE CONNECTION**

WATER SERVICE CONNECTION	WATER SERVICE CONNECTION	WATER SERVICE CONNECTION
WATER SERVICE CONNECTION	WATER SERVICE CONNECTION	WATER SERVICE CONNECTION
WATER SERVICE CONNECTION	WATER SERVICE CONNECTION	WATER SERVICE CONNECTION
WATER SERVICE CONNECTION	WATER SERVICE CONNECTION	WATER SERVICE CONNECTION
WATER SERVICE CONNECTION	WATER SERVICE CONNECTION	WATER SERVICE CONNECTION

- GENERAL PROJECT NOTES:**
1. ALL WORK SHALL BE IN ACCORDANCE WITH THE SPECIFICATIONS AND DRAWINGS.
  2. ALL MATERIALS SHALL BE OF THE HIGHEST QUALITY AVAILABLE.
  3. ALL WORK SHALL BE COMPLETED WITHIN THE SPECIFIED TIME FRAME.
  4. ALL WORK SHALL BE SUBJECT TO INSPECTION AND APPROVAL BY THE AUTHORITY.
  5. ALL WORK SHALL BE SUBJECT TO THE TERMS AND CONDITIONS OF THE CONTRACT.

- LEGEND:**
- 1. ALL WORK SHALL BE IN ACCORDANCE WITH THE SPECIFICATIONS AND DRAWINGS.
  - 2. ALL MATERIALS SHALL BE OF THE HIGHEST QUALITY AVAILABLE.
  - 3. ALL WORK SHALL BE COMPLETED WITHIN THE SPECIFIED TIME FRAME.
  - 4. ALL WORK SHALL BE SUBJECT TO INSPECTION AND APPROVAL BY THE AUTHORITY.
  - 5. ALL WORK SHALL BE SUBJECT TO THE TERMS AND CONDITIONS OF THE CONTRACT.

**SUMMARY OF WORK**

NO.	DESCRIPTION	QUANTITY	UNIT	AMOUNT
1	...	...	...	...
2	...	...	...	...
3	...	...	...	...
4	...	...	...	...
5	...	...	...	...
6	...	...	...	...
7	...	...	...	...
8	...	...	...	...
9	...	...	...	...
10	...	...	...	...
11	...	...	...	...
12	...	...	...	...
13	...	...	...	...
14	...	...	...	...
15	...	...	...	...
16	...	...	...	...
17	...	...	...	...
18	...	...	...	...
19	...	...	...	...
20	...	...	...	...
21	...	...	...	...
22	...	...	...	...
23	...	...	...	...
24	...	...	...	...
25	...	...	...	...
26	...	...	...	...
27	...	...	...	...
28	...	...	...	...
29	...	...	...	...
30	...	...	...	...
31	...	...	...	...
32	...	...	...	...
33	...	...	...	...
34	...	...	...	...
35	...	...	...	...
36	...	...	...	...
37	...	...	...	...
38	...	...	...	...
39	...	...	...	...
40	...	...	...	...
41	...	...	...	...
42	...	...	...	...
43	...	...	...	...
44	...	...	...	...
45	...	...	...	...
46	...	...	...	...
47	...	...	...	...
48	...	...	...	...
49	...	...	...	...
50	...	...	...	...
51	...	...	...	...
52	...	...	...	...
53	...	...	...	...
54	...	...	...	...
55	...	...	...	...
56	...	...	...	...
57	...	...	...	...
58	...	...	...	...
59	...	...	...	...
60	...	...	...	...
61	...	...	...	...
62	...	...	...	...
63	...	...	...	...
64	...	...	...	...
65	...	...	...	...
66	...	...	...	...
67	...	...	...	...
68	...	...	...	...
69	...	...	...	...
70	...	...	...	...
71	...	...	...	...
72	...	...	...	...
73	...	...	...	...
74	...	...	...	...
75	...	...	...	...
76	...	...	...	...
77	...	...	...	...
78	...	...	...	...
79	...	...	...	...
80	...	...	...	...
81	...	...	...	...
82	...	...	...	...
83	...	...	...	...
84	...	...	...	...
85	...	...	...	...
86	...	...	...	...
87	...	...	...	...
88	...	...	...	...
89	...	...	...	...
90	...	...	...	...
91	...	...	...	...
92	...	...	...	...
93	...	...	...	...
94	...	...	...	...
95	...	...	...	...
96	...	...	...	...
97	...	...	...	...
98	...	...	...	...
99	...	...	...	...
100	...	...	...	...


DATE: 10/10/2010




P-003

NO.	DESCRIPTION	QUANTITY	UNIT	AMOUNT
1	...	...	...	...
2	...	...	...	...
3	...	...	...	...
4	...	...	...	...
5	...	...	...	...
6	...	...	...	...
7	...	...	...	...
8	...	...	...	...
9	...	...	...	...
10	...	...	...	...
11	...	...	...	...

# Basis of Design – Chlorine Contact Basin (CCB)



As-Built CCB




Proposed Configuration


# Basis of Design – Chlorine Contact Basin (CCB)

Flow Speed Variation  
(Half Outer Tank, Units ft/s)

- Computational fluid dynamics (CFD) modeling performed
- Identified best improvements to CCB
- Modified CCB will provide 15 minutes contact time without reducing WRP flow capacity




As-Built CCB



Proposed Configuration

# Overview of Disinfection Facilities





# Agreement with Greeley and Hansen Contract 11-054-3P

Paul Vogel, Joe Gorgan, Catharine Richardson  
Andrew Martin, Roger Linde, Ryan Christopher

HAGAN, DAVID CIVIL SAN ASSOCIATE  
HOBBS, DAVID CIVIL SAN ASSOCIATE  
DAKHIL, MUSTAQ CIVIL SAN ENGINEER  
KERRIGAN, JAMES CIVIL SAN ENGINEER  
GOUDEAU, LAMONT CIVIL SAN DESIGNER  
VIRANYI, NORBERT ELECTRICAL ASSOCIATE  
ATKINSON, MARK ELECTRICAL ENGINEER  
SINGAL, SUBHASH ELECTRICAL ENGINEER  
WHITE, TONY ELECTRICAL ENGINEER  
CHAVEZ, OSCAR ELECTRICAL DRAFTER  
TIENSVOLD, TIMOTHY ELECTRICAL DRAFTER  
SMITH, GEORGE MECHANICAL ASSOCIATE  
JOHNSON, GLEN MECHANICAL ENGINEER  
POWELL, THOMAS INSTRUMENTATION  
KATEHIS, DIMITRIOS UMC PROFESSIONAL  
HAYES, DARIEN SUPPORT STAFF  
DAKHIL, MUSTAQ  
NICHOLS, WILLIAM  
GOUDEAU, LAMONT  
LEE, WAYNE  
HEBBE, DAVID

# Agreement with Greeley and Hansen Contract 11-054-3P

## **MBE/SBE Subconsultants**

Ground Engineering Consultants, Inc.  
MPR Engineering Corp, Inc.  
Rubinos & Mesia Engineers, Inc  
Vistara Construction Services, Inc

## **WBE/SBE Subconsultants**

Cotter Consulting, Inc.  
Environmental Design International, Inc.  
Intelligent Design and Construction Solutions, LLC  
Raimonde Drilling Corp.

## **Non-PCE Subconsultants**

Dr. Charles Haas, Drexel University  
Alden Research Laboratory

# Agreement with CH2M HILL Engineers, Inc. Contract 11-241-3P

Paul Swaim, Dave Baxter  
Tom Lachcik(ARCADIS)

CHRZANOWSKI, MARK FRANCIS  
ERIKSON, ANDREW C  
FISHER, JAMES H  
FOLEY, MICHAEL J.  
GILL, GRAHAM P  
GLAWTSCHIEW, THEODORE  
JEYANAYAGAM, SAMUEL  
PRATT, MARK H  
SCHMIDTKE, DEAN  
SRIVASTAVA, RAJEEV  
YOLO, ROGER A  
CARLSON, MARY L  
HOFFMAN, LISA DIANE  
LUCERO, TONI C  
RUDZINSKAS, CHRISTINE  
GAVIN, MATTHEW D  
HAMMERSCHMIDT, MARK  
KAVANAGH, AMY  
LAMONT, WENDY  
LANDERS, PAUL  
LEE, JONG WOOK  
TIAN, PING  
ZHAO, MINXING

# Agreement with CH2M HILL Engineers, Inc. Contract 11-241-3P

## **MBE/SBE Subconsultants**

Primera Engineers, Ltd.

M.P.R. Engineering Corp., Inc.

DB Sterlin Consultants, Inc.

Rubinos & Mesia Engineers, Inc.

Everest Engineering, Inc.

## **WBE/SBE Subconsultants**

Intelligent Design & Construction Solutions, LLC

Busking Engineering Services, Inc.

## **Non-PCE Subconsultant**

Arcadis- Malcolm Pirnie, Inc.



[How-to-draw-funny-cartoons.com](http://How-to-draw-funny-cartoons.com)

# Design Obstacles

## OWRP

- Existing underground facilities
- Transportation network (CTA) easement
- Above ground infrastructure
- Future expansion of Plant
- 4 – 72 hour Plant Shutdowns

## CWRP

- Existing underground facilities
- Current Plant Entrance
- Future expansion of Plant

# Contract 11-054-3P Disinfection Facilities OWRP

- 4 Volumes of Documents
- 204 Detailed Specification Sections
- 369 Contract Plan Drawings

# Contract 11-241-3P Disinfection Facilities CWRP

- 5 Volumes of Documents
- 160 Detailed Specification Sections
- 337 Contract Plan Drawings

# OWRP Contract Schedule

- Awarded August 8, 2013 to Walsh Construction Co.
- Contract Start August 22, 2013
- Construction Scheduled Completion August 22, 2015

How  
much?



Construction Cost:

**\$59.9 Million**

Maintenance & Operation Cost (Annually):

**\$2.07 Million**

# Calumet WRP Contract Schedule

- Awarded August 8, 2013 to IHC/KED, A Joint Venture
- Contract Start August 20, 2013
- Construction Scheduled Completion August 20, 2015

What  
will it  
cost?




Construction Cost:

**\$30.9 Million**

Maintenance & Operation Cost (Annually):

**\$3.55 Million**



**Questions?**